

Materialprüfungsamt Nordrhein-Westfalen

Prüfen • Überwachen • Zertifizieren

Certificate of constancy of performance**0432-CPR-00026-74**

Version 03

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Overhead door closer TS 68

Controlled door closing devices for single and double-leaf swing doors
as detailed and classified on annex 1

placed on the market under the name or trade mark of

dormakaba Deutschland GmbH

DORMA Platz 1
58256 Ennepetal, Germany

and produced in the manufacturing plant(s)

DO 2.5

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standard(s)

EN 1154:1996/A1:2002/AC:2006

under **system 1** for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 11.06.2019 and will remain valid until 11.06.2029 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Dortmund, 11.06.2024



By order

RBA Th. Meinks

Deputy Head of Certification Body Department
22.30

This Certificate consists of 1 page and 1 annex(es).

This certificate replaces certificate no. 0432-CPR-00026-74 from June 1st 2022,
version 02.

The original of this document was issued in German language.

In case of doubt only the German version is valid.

Materialprüfungsamt Nordrhein-Westfalen

Prüfen · Überwachen · Zertifizieren

List of Products

Type :	„TS 68“ and „TS 68 FRX“
Description :	Overhead door closer with hydraulic damping.
Arm system :	scissor arm
Mounting :	Door-leaf fixing, pull side (standard installation)
Size :	3/4
Classification / mounting :	3 8 3/4 1 1 2 Door-leaf fixing, pull side (standard installation)
Manufacturing plant :	DO 2.5
Remarks :	---

Intended use:

for single and double-leaf fire- and/or smoke protection swingdoors

Essential characteristics	Clauses with requirements in EN 1154:1996/A1:2002/AC:2006	Performance of product
Self-closing	5.2.1 General 5.2.3 Closing torque 5.2.4 Opening torque 5.2.5 Efficiency 5.2.6 Closing time 5.2.7 Opening angle Door-leaf fixing, pull side 5.2.8 Overload test 5.2.9 Temperature dependence 5.2.10 Leakage 5.2.11 Damage 5.2.12 Latch regulation 5.2.13 Back check 5.2.14 Delayed action 5.2.15 Adjustable force 5.2.16 Free play at zero point position 5.2.18 Use on fire-/smoke protection doors	passed passed (Size 3/4) passed (Size 3/4) passed (Size 3/4) passed (Size 3/4) passed (Class 3) passed (Size 3/4) passed (Size 3/4) passed (Size 3/4) passed (Size 3/4) passed (Size 3/4) not applicable not applicable passed (Size 3/4) not applicable Class 1: passed
Durability Self-closing	5.2.2 durability 5.2.17.1 corrosion resistance 5.2.17.2 corrosion resistance 5.2.17.3 corrosion resistance	Class 8 (500 000 cycles): passed Class 2 (48h): passed Class 2 (48h): passed Class 2 (48h): passed
Dangerous substances	Annex ZA.3	The manufacturer has not declared any dangerous substances.